

Public-law institution jointly founded by the federal states and the Federation

European Technical Assessment Body
for construction products



European Technical Assessment

ETA-20/0867
of 11 February 2025

English translation prepared by DIBt - Original version in German language

General Part

Technical Assessment Body issuing the European Technical Assessment:

Trade name of the construction product

Product family
to which the construction product belongs

Manufacturer

Manufacturing plant

This European Technical Assessment contains

This European Technical Assessment is issued in accordance with Regulation (EU) No 305/2011, on the basis of

This version replaces

Deutsches Institut für Bautechnik

Hilti screw anchor HUS4

Mechanical fastener for use in concrete

Hilti AG
Feldkircherstraße 100
9494 Schaan
FÜRSTENTUM LIECHTENSTEIN

Hilti Werke

46 pages including 3 annexes which form an integral part of this assessment

EAD 330232-01-0601-v05, Edition 01/2024

ETA-20/0867 issued on 25 April 2024

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

Specific Part

1 Technical description of the product

The Hilti screw anchor HUS4 is an anchor in size 8, 10, 12, 14 and 16 mm made of galvanized and stainless steel. The anchor is screwed into a predrilled cylindrical drill hole. The special thread of the anchor cuts an internal thread into the member while setting. The anchorage is characterised by mechanical interlock in the special thread.

Product and product description are given in Annex A.

2 Specification of the intended use in accordance with the applicable European Assessment Document

The performances given in Section 3 are only valid if the anchor is used in compliance with the specifications and conditions given in Annex B.

The verifications and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of the anchor of at least 50 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

3 Performance of the product and references to the methods used for its assessment

3.1 Mechanical resistance and stability (BWR 1)

Essential characteristic	Performance
Characteristic resistance to tension load (static and quasi-static loading)	See Annex B5 to B9, Annex C1, C3, C5 and C7
Characteristic resistance to shear load (static and quasi-static loading)	See Annex C2, C4, C6 and C7
Displacements (static and quasi-static loading)	See Annex C21 to C23
Characteristic resistance and displacements for seismic performance categories C1 and C2	See Annex C8 to C13 and C24

3.2 Safety in case of fire (BWR 2)

Essential characteristic	Performance
Reaction to fire	Class A1
Resistance to fire	See Annex C14 to C20

3.3 Aspects of durability linked with the Basic Works Requirements

Essential characteristic	Performance
Durability	See Annex B1

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

In accordance with European Assessment Document EAD No. 330232-01-0601-v05 the applicable European legal act is: [96/582/EC].

The system to be applied is: 1

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable European Assessment Document


Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited at Deutsches Institut für Bautechnik.

Issued in Berlin on 11 February 2025 by Deutsches Institut für Bautechnik

Dipl.-Ing. Beatrix Wittstock
Head of Section

beglaubigt:
Tempel

Installed condition without adjustment




HUS4-H (hexagon head configuration sizes 8, 10, 12, 14 and 16)

HUS4 T-H (hexagon head configuration sizes 8 and 10)

HUS4-HF (hexagon head configuration sizes 8, 10, 12, 14 and 16)

HUS4 T-HF (hexagon head configuration sizes 8 and 10)


HUS4-HR (hexagon head configuration sizes 6, 8, 10 and 14)



HUS4 C (countersunk head configuration sizes 8 and 10)

HUS4 T-C (countersunk head configuration sizes 8 and 10)


HUS4-CR (countersunk head configuration size 6, 8 and 10)



HUS4-A
(threaded rod connection
sizes 10 with M12 and 14 with M16)

HUS4-AF
(threaded rod connection
sizes 10 with M12 and 14 with M16)

Installed condition with adjustment




HUS4-H (hexagon head configuration sizes 8, 10, 12 and 14)

HUS4 T-H (hexagon head configuration sizes 8 and 10)

HUS4-HF (hexagon head configuration sizes 8, 10, 12 and 14)

HUS4 T-HF (hexagon head configuration sizes 8 and 10)



HUS4-C (countersunk head configuration sizes 8 and 10)

HUS4 T-C (countersunk head configuration sizes 8 and 10)

Hilti screw anchor HUS4

Product description

Installed condition with and without adjustment

Annex A1

Table A1: Screw types

Hilti HUS4-H, sizes 8,10, 12, 14 and 16, hexagonal head configuration, carbon steel galvanized
Hilti HUS4-HF, sizes 8,10, 12, 14 and 16, hexagonal head configuration, carbon steel multilayer coating



Hilti HUS4 T-H, sizes 8 and 10 hexagonal head configuration, carbon steel galvanized
Hilti HUS4 T-HF, sizes 8 and 10, hexagonal head configuration, carbon steel multilayer coating




Hilti HUS4-HR, sizes 6, 8, 10 and 14 hexagonal head configuration, stainless steel




Hilti HUS4-C, sizes 8 and 10, countersunk head configuration, carbon steel galvanized



Hilti HUS4 T-C, sizes 8 and 10, countersunk head configuration, carbon steel galvanized



Hilti HUS4-CR, sizes 6, 8 and 10 countersunk head configuration, stainless steel



Hilti HUS4-A, size 10 with external thread M12 and size 14 with external thread M16, carbon steel galvanized
Hilti HUS4-AF, size 10 with external thread M12 and size 14 with external thread M16, carbon steel multilayer coating



Hilti screw anchor HUS4

Product description
HUS4 screw types

Annex A2

Table A2: Hilti filling set (for HUS4 (T)-H(F, R) and HUS4-A (F)) and Hilti injection mortar



Filling washer	Spherical washer	Injection mortar
		 Hilti HIT-HY ... with ETA Hilti HIT-RE ... with ETA

Table A3: Materials

Part	Material
HUS4 (T)-H(F), HUS4 (T)-C and HUS4-A(F) screw anchor	Carbon steel Rupture elongation $A_5 \leq 8\%$
HUS4-HR and HUS-CR	Stainless steel (A4 grade) Rupture elongation $A_5 > 8\%$ Stainless steel of corrosion resistance class CRC III according to EN 1993-1-4:2006+A1:2015 1.4401 or 1.4404 according to EN 10088-1:2014
Hilti Filling set (carbon steel)	Filling washer: Carbon steel Spherical washer: Carbon steel
Hilti Filling set (stainless steel)	Corrosion resistance class CRC III according to EN 1993-1-4:2006+A1:2015 Filling washer: Stainless steel A4 according to ASTM A240/A 240M:2019 Spherical washer: Stainless steel A4 according to EN 10088-1:2014

Hilti screw anchor HUS4

Product description

HUS4 screw types, Filling set and Hilti injection mortar
Materials

Annex A3

Table A4: Filling set dimensions

Filling set size	M10	M12	M16	M20	
Diameter d_{vs} [mm]	42	44	52	60	
Thickness h_{vs} [mm]	5	5	6	6	
HUS4 (T)-H (F, R)	8	10	$12 + 14$	16	
HUS4-A (F)	-	10	14	-	





Table A5: Fastener dimensions and marking HUS4-A(F)

Fastener size HUS4-	A(F) 10			A(F) 14			
Nominal fastener diameter d [mm]	10			14			
Metric thread connection	M12			M16			
Pitch of the thread h_t [mm]	10			14			
Nominal embedment depth h_{nom} [mm]	h_{nom1}	h_{nom2}	h_{nom3}	h_{nom1}	h_{nom2}	h_{nom3}	
	55	75	85	65	85	115	
Effective embedment depth h_{ef} [mm]	$h_{ef} = 0,85 * (h_{nom} - 5) \leq h_{ef,max}$			$h_{ef} = 0,85 * (h_{nom} - 7) \leq h_{ef,max}$			
Limits of effective embedment depth $h_{ef,max}$ [mm]	68,0			91,8			
Length of screw min / max	L	[mm]	120 / 165			155 / 205	



Hilti screw anchor HUS4

Production description
Fastener dimensions and head marking

Annex A4

English translation prepared by DIBt

Table A6: Fastener dimensions and marking HUS4 (T)-H(F)

Fastener size HUS4-	H(F) 8			T-H(F) 8			H(F) 10			T-H(F) 10		
Nominal fastener diameter d [mm]	8			8			10			10		
Pitch of the thread h _t [mm]	8			8			10			10		
Nominal embedment depth h _{nom} [mm]	h _{nom1}	h _{nom2}	h _{nom3}	h _{nom1}	h _{nom2}	h _{nom3}	h _{nom1}	h _{nom2}	h _{nom3}	h _{nom1}	h _{nom2}	h _{nom3}
	40	60	70	50	60	70	55	75	85	55	75	85
Effective embedment depth h _{ef} [mm]	$0,85 * (h_{nom} - 4,0) \leq h_{ef,max}$			$0,85 * (h_{nom} - 5,45) \leq h_{ef,max}$			$0,85 * (h_{nom} - 5,0) \leq h_{ef,max}$			$0,85 * (h_{nom} - 6,1) \leq h_{ef,max}$		
Limits of effective embedment depth h _{ef,max} [mm]	56,1			54,9			68,0			67,1		
Length of screw min / max L [mm]	45 / 150			55 / 150			60 / 305			60 / 150		

Fastener size HUS4-	H(F) 12			H(F) 14			H(F) 16			
Nominal fastener diameter d [mm]	12			14			16			
Pitch of the thread h _t [mm]	12			14			13,2			
Nominal embedment depth h _{nom} [mm]	h _{nom1}	h _{nom2}	h _{nom3}	h _{nom1}	h _{nom2}	h _{nom3}	h _{nom1}	h _{nom2}		
	60	80	100	65	85	115	85	130		
Effective embedment depth h _{ef} [mm]	$h_{ef} = 0,85 * (h_{nom} - 6,0) \leq h_{ef,max}$			$h_{ef} = 0,85 * (h_{nom} - 7,0) \leq h_{ef,max}$			$h_{ef} = 0,85 * (h_{nom} - 6,6) \leq h_{ef,max}$			
Limits of effective embedment depth h _{ef,max} [mm]	79,9			91,8			104,9			
Length of screw min / max L [mm]	70 / 150			75 / 150			100 / 205			


Hilti screw anchor HUS4

Production description
Fastener dimensions and head marking

Annex A5

Table A7: Fastener dimensions and marking HUS4-HR

Fastener size HUS4-	HR 6	HR 8		HR 10		HR 14	
Nominal fastener diameter d [mm]	6	8		10		14	
Pitch of the thread h _t [mm]	4,75	7,6		8,0		9,8	
Nominal embedment depth h _{nom} [mm]	h _{nom1}	h _{nom1}	h _{nom2}	h _{nom1}	h _{nom2}	h _{nom1}	h _{nom2}
	55	60	80	70	90	70	110
Effective embedment depth h _{ef} [mm]	0,85 * (h _{nom} – 2,37) ≤ h _{ef,max}	0,85 * (h _{nom} – 4,8) ≤ h _{ef,max}		0,85 * (h _{nom} – 6,4) ≤ h _{ef,max}		0,85 * (h _{nom} – 9,0) ≤ h _{ef,max}	
Limits of effective embedment depth h _{ef,max} [mm]	45	64		71		86	
Length of screw min / max L [mm]	60 / 70	65 / 105		75 / 130		80 / 135	

		HUS4: Hilti Universal Screw 4 th generation
		(T)-H: Hexagonal head, galvanized
		(T)-HF: Hexagonal head, multilayer coating
		HR: Hexagonal head, stainless steel
		10: Nominal screw diameter d [mm]
		100: Length of screw [mm]

Hilti screw anchor HUS4


Production description
Fastener dimensions and head marking

Annex A6

Table A8: Fastener dimensions and marking HUS4 (T)-C(R)

Fastener size HUS4-			C 8			T-C 8			C 10			T-C 10		
Nominal fastener diameter	d	[mm]	8			8			10			10		
Pitch of the thread	h_t	[mm]	8			8			10			10		
Nominal embedment depth	h_{nom}	[mm]	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$
			40	60	70	50	60	70	55	75	85	55	75	85
Effective embedment depth	h_{ef}	[mm]	$0,85 * (h_{\text{nom}} - 4) \leq h_{\text{ef,max}}$			$0,85 * (h_{\text{nom}} - 5,45) \leq h_{\text{ef,max}}$			$0,85 * (h_{\text{nom}} - 5) \leq h_{\text{ef,max}}$			$0,85 * (h_{\text{nom}} - 6,1) \leq h_{\text{ef,max}}$		
Limits of effective embedment depth	$h_{\text{ef,max}}$	[mm]	56,1			54,9			68,0			67,1		
Length of screw min / max	L	[mm]	55 / 160			65 / 85			70 / 180			70 / 305		

Fastener size HUS4-			CR 6			CR 8			CR 10				
Nominal fastener diameter	d	[mm]	6			8			10				
Pitch of the thread	h_t	[mm]	-			7,6			8,0				
Nominal embedment depth	h_{nom}	[mm]	$h_{\text{nom}2}$			$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$				
			55			60	80	70	90				
Effective embedment depth	h_{ef}	[mm]	$0,85 * (h_{\text{nom}} - 2,37) \leq h_{\text{ef,max}}$			$0,85 * (h_{\text{nom}} - 4,8) \leq h_{\text{ef,max}}$			$0,85 * (h_{\text{nom}} - 6,4) \leq h_{\text{ef,max}}$				
Limits of effective embedment depth	$h_{\text{ef,max}}$	[mm]	45			64			71				
Length of screw min / max	L	[mm]	60 / 70			65 / 95			75 / 105				



Hilti screw anchor HUS4

Production description
Fastener dimensions and head marking

Annex A7

Specifications of intended use

Anchorage subject to:

- Static and quasi-static loadings
- Seismic action for performance category C1 and C2 for HUS4 (T)-H(F)/-C/-A(F) (carbon steel screw)
- Seismic action for performance category C1: HUS4-HR/-CR (stainless steel screw)
- Fire exposure

Base materials:

- Compacted reinforced or unreinforced normal weight concrete according to EN 206:2013+A1:2016.
- Strength classes C20/25 to C50/60 according to EN 206:2013+A1:2016.
- Cracked and uncracked concrete.
- The fastener is intended to be used in fibre reinforced concrete according to EN 206:2013+A2:2021 including steel fibres (SFRC) according to EN 14889-1:2006 clause 1, group I. The maximum content of steel fibres is 80 kg/m³.

Use conditions (Environmental conditions):

- Anchorage subject to dry internal conditions: all screw types
- For all other conditions corresponding to corrosion resistance classes CRC according to EN 1993-1-4:2006+A1:2015
 - Stainless steel according to Annex A3 Table A3, screw types HUS4-HR/-CR: CRC III

Design:

- Anchorages are designed under the responsibility of an engineer experienced in anchorages and concrete work.
- Verifiable calculation notes and drawings are prepared taking account of the loads to be anchored. The position of the fastener is indicated on the design drawings (e. g. position of the fastener relative to reinforcement or to supports, etc.).
- Anchorages are designed in accordance with:
EN 1992-4:2018 and EOTA Technical Report TR 055 edition February 2018.
- In case of requirements to resistance to fire local spalling of the concrete cover must be avoided.
- The design method according to EN 1992-4:2018 applies for use in Steel Fibre Reinforced Concrete (SFRC) with the essential characteristics as specified for plain concrete without fibres.

Installation:

- Fastener installation carried out by appropriately qualified personnel and under the supervision of the person responsible for technical matters on site.
- In case of aborted hole: new drilling at a minimum distance away of twice the depth of the aborted hole or smaller distance if the aborted hole is filled with high strength mortar and if under shear or oblique tension load it is not the direction of the load application.
- After installation further turning of the fastener must not be possible.
- The head of the fastener (HUS4 (T)-H (F, R) and HUS4 (T)-C/-CR) must be supported on the fixture and is not damaged.
- Hilti filling set is suitable for HUS4 (T)-H (F, R) and HUS4-A (F)

Hilti screw anchor HUS4

Intended use
Specifications

Annex B1

Specifications of intended use: Drilling and cleaning for HUS4 carbon steel

Table B1: HUS4 (T)-H(F)/-C/-A(F) intended use for static and quasi static loading

HUS4 (T)-H(F)/-C/-A(F) carbon steel	Fastener size and embedment depth h_{nom}	
Cracked and uncracked concrete		
Hammer drilling (HD) ¹⁾	cleaned	sizes 8 to 16 at all h_{nom}
	not cleanded	sizes 8 to 14 at all h_{nom}
Hammer drilling with Hilti hollow drill bit TE-CD (HDB) ¹⁾		sizes 12 and 14 at all h_{nom}
Uncracked concrete		
Diamond coring (DD) DD30-W handheld and with stand DD-EC1 handheld		sizes 10 to 14 at h_{nom}^3 (HUS4 T excluded)

¹⁾ Adjustment according to Annex B11 is possible for sizes 8 to 10 at h_{nom2+3} and 12 to 14 at all h_{nom}

Table B2: HUS4 (T)-H(F)/-C/-A(F) intended use for seismic performance category C1

HUS4 (T)-H(F)/-C/-A(F) carbon steel	Fastener size and embedment depth h_{nom}	
Hammer drilling (HD) ¹⁾	cleaned	sizes 8 to 16 at all h_{nom} (HUS4 8 at h_{nom1} excluded)
	not cleanded	sizes 8 to 14 at all h_{nom} (HUS4 8 at h_{nom1} excluded)
Hammer drilling with Hilti hollow drill bit TE-CD (HDB) ¹⁾		sizes 12 and 14 at all h_{nom}

¹⁾ Adjustment according to Annex B11 is possible for sizes 8 to 10 at h_{nom2+3} and 12 to 14 at all h_{nom}

Table B3: HUS4 (T)-H(F)/-C/-A(F) intended use for seismic performance category C2

HUS4 (T)-H(F)/-C/-A(F) carbon steel	Fastener size and embedment depth h_{nom}	
Hammer drilling (HD) ¹⁾	Cleaned and not cleanded	sizes 8 to 14 at all h_{nom} (HUS4 8 at h_{nom1} excluded)

¹⁾ Adjustment according to Annex B11 is possible for sizes 8 to 10 at h_{nom2+3} and 12 to 14 at all h_{nom}

Table B4: HUS4 (T)-H(F)/-C/-A(F) intended use for static and quasi static loading under fire exposure

HUS4 (T)-H(F)/-C/-A(F) carbon steel	Fastener size and embedment depth h_{nom}	
Hammer drilling (HD) ¹⁾	cleaned	sizes 8 to 16 at all h_{nom}
	not cleanded	sizes 8 to 14 at all h_{nom}
Hammer drilling with Hilti hollow drill bit TE-CD (HDB) ¹⁾		sizes 12 and 14 at all h_{nom}


¹⁾ Adjustment according to Annex B11 is possible for sizes 8 to 10 at h_{nom2+3} and 12 to 14 at all h_{nom}

Hilti screw anchor HUS4

Intended use
Specifications

Annex B2

Table B5: Intended use for HUS4 (T)-H(F)/-C/-A(F) in concrete with SFRC (seismic category C2 is excluded)

HUS4 (T)-H(F)/-C/-A(F) carbon steel	Fastener size and embedment depth h_{nom}	
Cracked and uncracked concrete		
Hammer drilling (HD) ¹⁾	cleaned	sizes 8 to 16 at all h_{nom}
	not cleanded	sizes 8 to 14 at all h_{nom}
Hammer drilling with Hilti hollow drill bit TE-CD (HDB) ¹⁾		sizes 12 and 14 at all h_{nom}
Uncracked concrete		
Diamond coring (DD) DD30-W handheld and with stand DD-EC1 handheld		sizes 10 to 14 at h_{nom}^3 (HUS4 T excluded)

¹⁾ Adjustment according to Annex B11 is possible for sizes 8 to 10 at h_{nom2+3} and 12 to 14 at all h_{nom}

Specifications of intended use: Drilling and cleaning for HUS4 stainless steel

Table B6: HUS4-HR/-CR intended use for static and quasi static loading

HUS4-HR/-CR stainless steel	Fastener size and embedment depth h_{nom}	
Cracked and uncracked concrete		
Hammer drilling (HD)	cleaned	sizes 6 to 14 at all h_{nom}
	not cleanded	

Table B7: HUS4-HR/-CR intended use for seismic performance category C1

HUS4-HR/-CR stainless steel	Fastener size and embedment depth h_{nom}	
Hammer drilling (HD)	cleaned	sizes 8 to 14 at h_{nom2}
	not cleanded	

Table B8: HUS4-HR/-CR intended use for static and quasi static loading under fire exposure


HUS4-HR/-CR stainless steel	Fastener size and embedment depth h_{nom}	
Hammer drilling (HD)	cleaned	sizes 6 to 14 at all h_{nom}
	not cleanded	

Hilti screw anchor HUS4

**Intended use
Specifications**

Annex B3

Installation parameters



Hilti screw anchor HUS4

Intended use
Installation parameters

Annex B4

Table B9: Installation parameters HUS4 8 and 10

Fastener size HUS4 Type		8 H(F), C			8 T-H(F), C			10 H(F), C, A(F)		
		$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$
Nominal embedment depth	h_{nom} [mm]	40	60	70	50	60	70	55	75	85
Nominal drill hole diameter	d_0 [mm]		8			8			10	
Cutting diameter of drill bit	$d_{\text{cut}} \leq$ [mm]		8,45			8,45			10,45	
Cutting diameter of diamond core bit	$d_{\text{cut}} \leq$ [mm]		-			-			9,9	
Clearance hole diameter through setting	d_f _{min} ^{max} [mm]		11			11			13	
			12			12			14	
Clearance hole diameter pre setting (A-type)	$d_f \leq$ [mm]		-			-			14	
Wrench size (H, HF-type)	s [mm]		13			13			15	
Wrench size for hex head (A-type)	s_1 [mm]		-			-			8	
Wrench size for nut (A-type)	s_2 [mm]		-			-			19	
Maximum installation torque (A-type)	$\text{max } T_{\text{inst}}$ [Nm]		-			-			40	
Torx size (C-type)	TX	-	45			45			50	
Diameter of countersunk head	d_h [mm]		18			18			21	
Depth of drill hole for cleaned hole hammer drilling, diamond coring or for uncleared hole when drilling upwards	$h_1 \geq$ [mm]		$(h_{\text{nom}} + 10 \text{ mm})$							
			50	70	80	60	70	80	65	85
Depth of drill hole for uncleared hole hammer drilling in wall and floor position	$h_1 \geq$ [mm]		$(h_{\text{nom}} + 10 \text{ mm}) + 2 * d_0$							
			66	86	96	76	86	96	85	105
Depth of drill hole (with adjustability) for cleaned hole hammer drilling, diamond coring or for uncleared hole when drilling upwards	$h_1 \geq$ [mm]		$(h_{\text{nom}} + 20 \text{ mm})$							
			-	80	90	70	80	90	-	95
Depth of drill hole (with adjustability) for uncleared hole hammer drilling in wall and floor position	$h_1 \geq$ [mm]		$(h_{\text{nom}} + 20 \text{ mm}) + 2 * d_0$							
			-	96	106	86	96	106	-	115
Minimum thickness of concrete member	$h_{\text{min}} \geq$ [mm]		$(h_1 + 30 \text{ mm})$							
			80	100	120	100	100	120	100	130
Minimum spacing	$s_{\text{min}} \geq$ [mm]		35		50 ²⁾	50	50		40	
Minimum edge distance	$c_{\text{min}} \geq$ [mm]		35		40	40	40		40	
Hilti Setting tool ¹⁾			SIW 4(AT)-22 1/2" SIW 6(AT)-A22 1/2" SIW 6(AT)-22 1/2" gear 1						SIW 6(AT)-22 1/2" SIW 22T-A 1/2" SIW 8-22 1/2" gear 1 SIW 9-A22 3/4"	

¹⁾ Installation with other impact screw driver of equivalent power is possible.

²⁾ $s_{\text{min}} = 40 \text{ mm}$ is possible if $c_{\text{min}} \geq 50 \text{ mm}$.

Hilti screw anchor HUS4

Intended use
Installation parameters

Annex B5

Table B10: Installation parameters HUS4 10 to 14

Fastener size HUS4	Type	h _{nom} [mm]	10			12			14		
			T-H(F), C			H(F)			H(F), A(F)		
Nominal embedment depth		h _{nom} [mm]	55	75	85	60	80	100	65	85	115
Nominal drill hole diameter	d ₀	[mm]		10			12			14	
Cutting diameter of drill bit	d _{cut} ≤	[mm]		10,45			12,50			14,50	
Cutting diameter of diamond core bit	d _{cut} ≤	[mm]		-			12,2			14,2	
Clearance hole diameter through setting	d _f $\frac{\text{min}}{\text{max}}$ [mm]			14			16			18	
Clearance hole diameter pre setting (A-type)	d _f ≤	[mm]		-			-			18	
Wrench size (H, HF-type)	s	[mm]		15			17			21	
Wrench size for hex head (A-type)	s ₁	[mm]		-			-			12	
Wrench size for nut (A-type)	s ₂	[mm]		-			-			24	
Maximum installation torque (A-type)	max T _{inst}	[Nm]		-			-			80	
Torx size (C-type)	TX	-		50			-			-	
Diameter of countersunk head	d _h	[mm]		21			-			-	
Depth of drill hole for cleaned hole hammer drilling, diamond coring or for uncleared hole when drilling upwards	h ₁ ≥	[mm]		(h _{nom} + 10 mm)							
				65	85	95	70	90	110	75	95
Depth of drill hole for uncleared hole hammer drilling in wall and floor position	h ₁ ≥	[mm]		(h _{nom} + 10 mm) + 2 * d ₀							
				85	105	115	94	114	134	103	123
Depth of drill hole (with adjustability) for cleaned hole hammer drilling, diamond coring or for uncleared hole when drilling upwards	h ₁ ≥	[mm]		(h _{nom} + 20 mm)							
				75	95	105	-	100	120	-	105
Depth of drill hole (with adjustability) for uncleared hole hammer drilling in wall and floor position	h ₁ ≥	[mm]		(h _{nom} + 20 mm) + 2 * d ₀							
				95	115	125	-	124	144	-	133
Minimum thickness of concrete member	h _{min} ≥	[mm]		(h ₁ + 30 mm)							
				100	130	140	110	130	150	120	160
Minimum spacing	s _{min} ≥	[mm]		50			50			60	
Minimum edge distance	c _{min} ≥	[mm]		50			50			60	
Hilti Setting tool ¹⁾				SIW 6(AT)-22 1/2"	SIW 22T-A 1/2"		SIW 6(AT)-22 1/2"			SIW 22T-A 1/2"	
				SIW 22T-A 1/2"	SIW 6(AT)-22 1/2"		SIW 8-22 1/2"			SIW 6(AT)-22 1/2"	
				SIW 8-22 1/2"	SIW 8-22 1/2"		gear 1			SIW 8-22 1/2"	
				SIW 9-A22 3/4"	SIW 9-A22 3/4"		SIW 9-A22 3/4"			SIW 9-A22 3/4"	

¹⁾ Installation with other impact screw driver of equivalent power is possible.

Hilti screw anchor HUS4

Intended use
Installation parameters

Annex B6

Table B11: Installation parameters HUS4-16

Fastener size HUS4			16	
Type			H(F)	
			$h_{\text{nom}1}$	$h_{\text{nom}2}$
Nominal embedment depth	h_{nom}	[mm]	85	130
Nominal drill hole diameter	d_0	[mm]		16
Cutting diameter of drill bit	$d_{\text{cut}} \leq$	[mm]		16,50
Clearance hole diameter through setting	$d_f \leq$	[mm]		20
Wrench size	s	[mm]		24
Depth of drill hole for cleaned hole hammer drilling or for uncleared hole when drilling upwards	$h_1 \geq$	[mm]	$(h_{\text{nom}} + 10 \text{ mm})$	
			95	140
Minimum thickness of concrete member	$h_{\text{min}} \geq$	[mm]	130	195
Minimum spacing	$s_{\text{min}} \geq$	[mm]		90
Minimum edge distance	$c_{\text{min}} \geq$	[mm]		65
Hilti Setting tool ¹⁾			SIW 22T-A 1/2" SIW 6(AT)-22 1/2" SIW 8-22 1/2" SIW 9-A22 3/4"	

¹⁾ Installation with other impact screw driver of equivalent power is possible.

Hilti screw anchor HUS4

Intended use
Installation parameters

Annex B7

Table B12: Installation parameters HUS4-HR/-CR 6 and 8

Fastener size HUS4	6	8	
Type	HR, CR	HR, CR	
Nominal embedment depth h_{nom} [mm]	$h_{\text{nom}1}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$
Nominal drill hole diameter d_0 [mm]	55	60	80
Cutting diameter of drill bit $d_{\text{cut}} \leq$ [mm]	6,40	8,45	
Clearance hole diameter $d_f \leq$ [mm]	9	12	
Wrench size (H-type) s [mm]	13	13	
Torx size (C-type) TX [-]	30	45	
Diameter of countersunk head d_h [mm]	11	18	
Depth of drill hole for cleaned hole hammer drilling or for uncleared hole when drilling upwards $h_1 \geq$ [mm]	$(h_{\text{nom}} + 10\text{mm})$		
	65	70	90
Depth of drill hole for uncleared hole hammer drilling in wall and floor position $h_1 \geq$ [mm]	$(h_{\text{nom}} + 10\text{ mm}) + 2 * d_0$		
	77	86	106
Minimum thickness of concrete member $h_{\text{min}} \geq$ [mm]	$(h_1 + 30\text{ mm})$		
	100	100	120
Minimum spacing $s_{\text{min}} \geq$ [mm]	35	45	50
Minimum edge distance $c_{\text{min}} \geq$ [mm]	35	45	50
Hilti Setting tool ¹⁾	SIW 6(AT)-A22 1/2" SIW 4(AT)- 22 1/2" SIW 6(AT)-22 1/2"	SIW 22T-A 1/2" SIW 6(AT)-A22 1/2" SIW 4(AT)- 22 1/2" SIW 6(AT)-22 1/2"	

¹⁾ Installation with other impact screw driver of equivalent power is possible.

Hilti screw anchor HUS4

Intended use
Installation parameters

Annex B8

Table B13: Installation parameters HUS4-HR/-CR 10 and 14

Fastener size HUS4		10		14	
Type		HR, CR		HR	
Nominal embedment depth	h_{nom} [mm]	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$
		70	90	70	110
Nominal drill hole diameter	d_0 [mm]		10		14
Cutting diameter of drill bit	$d_{\text{cut}} \leq$ [mm]		10,45		14,50
Clearance hole diameter	$d_f \leq$ [mm]		14		18
Wrench size (H-type)	s [mm]		15		21
Torx size (C-type)	TX [-]		50		-
Diameter of countersunk head	d_h [mm]		21		-
Depth of drill hole for cleaned hole hammer drilling, diamond coring or for uncleaned hole when drilling upwards	$h_1 \geq$ [mm]	$(h_{\text{nom}} + 10\text{mm})$			
		80	100	80	120
Depth of drill hole for uncleaned hole hammer drilling in wall and floor position	$h_1 \geq$ [mm]	$(h_{\text{nom}} + 10\text{ mm}) + 2 * d_0$			
		100	120	108	148
Installation Torque	T_{inst} [Nm]	45		65	
Minimum thickness of concrete member	$h_{\text{min}} \geq$ [mm]	120	140	140	160
Minimum spacing	$s_{\text{min}} \geq$ [mm]	50		50	60
Minimum edge distance	$c_{\text{min}} \geq$ [mm]	50		50	60
Hilti Setting tool ¹⁾		SIW 22T-A 1/2" SIW 6(AT)-A22 1/2" SIW 4(AT)- 22 1/2" SIW 6(AT)-22 1/2"		SIW 22T-A 1/2" SIW 6(AT)-22 1/2" SIW 8-22 1/2" gear 1 SIW 9-A22 3/4"	

¹⁾ Installation with other impact screw driver of equivalent power is possible.

Hilti screw anchor HUS4


Intended use
Installation parameters

Annex B9


Installation instructions

Hole drilling and cleaning


Hammer drilling (HD) all sizes for carbon and stainless steel screw types (size 16 with cleaning only)



Mark drilling depth h_1 for pre or through installation.
Details for drilling depth h_1 see table B5 to B9.




Cleaning needed in downward and horizontal installation direction with drill hole depth:
 $h_1 = h_{\text{nom}} + 10 \text{ mm}$




No cleaning is allowed in upward installation direction.
No cleaning is allowed in downward and horizontal installation direction when 3x ventilation¹⁾ after drilling is executed.
Drill hole depth $h_1 = h_{\text{nom}} + 10 \text{ mm} + 2 * d_0$
¹⁾ moving the drill bit in and out of the drill hole 3 times after the recommended drilling depth h_1 is achieved. This procedure shall be done with both revolution and hammer functions activated in the drilling machine. For more details read the relevant installation instruction (MPII).

Hammer drilling with Hilti hollow drill bit (HDB) TE-CD size 12 and 14 for carbon steel screw types



No cleaning needed.
 $h_1 = h_{\text{nom}} + 10 \text{ mm}$

Diamond coring with DD-EC1 or DD-30W size 10 to 14 for carbon steel screw types



Cleaning needed in all installation directions.
 $h_1 = h_{\text{nom}} + 10 \text{ mm}$


Hilti screw anchor HUS4

Intended use
Installation instructions

Annex B10


Fastener setting without adjustment

Setting by impact screw driver




Setting parameters listed in Table B5 to B7.

Setting check




Fastener setting with adjustment for carbon steel screw types

Adjusting process




A screw can be adjusted maximum two times. The total allowed thickness of shims added during the adjustment process is 10 mm. The final embedment depth after adjustment process must be larger or equal than the required one of h_{nom1} , h_{nom2} or h_{nom3} .

Fastener setting with Hilti filling set



Injection of Hilti HIT mortar and curing time



Fill the annular gap between screw and fixture with 1-3 strokes of a Hilti injection mortar HIT-HY ... or HIT-RE
Follow the installation instructions supplied with the respective Hilti injection mortar.
After required curing time t_{cure} the fastening can be loaded.

Hilti screw anchor HUS4

Intended use Installation instructions

Annex B11

Table C1: Essential characteristics under static and quasi-static load in concrete for HUS4 carbon steel size 8 and 10

Fastener size HUS4		8			8			10							
Type		H(F), C			T-H(F), T-C			H(F), C, A(F)							
		h_{nom1}	h_{nom2}	h_{nom3}	h_{nom1}	h_{nom2}	h_{nom3}	h_{nom1}	h_{nom2}	h_{nom3}					
Nominal embedment depth	h_{nom} [mm]	40	60	70	50	60	70	55	75	85					
Adjustment															
Total max. thickness of adjustment layers	t_{adj} [mm]	-	10	10	-	10	10	-	10	10					
Max. number of adjustments	n_a [-]	-	2	2	-	2	2	-	2	2					
Steel failure for tension load															
Characteristic resistance	$N_{Rk,s}$ [kN]	36,0			39,2			55,0							
Partial factor	$\gamma_{Ms,N}^{1)}$ [-]	1,5			1,4			1,5							
Pull-out failure															
Characteristic resistance in uncracked concrete C20/25	$N_{Rk,p,ucr}$ [kN]	$\geq N_{Rk,c}^0$ ³⁾			9	12	16	13	22	$\geq N_{Rk,c}^0$ ³⁾					
Characteristic resistance in cracked concrete C20/25	$N_{Rk,p,cr}$ [kN]	5,5	$\geq N_{Rk,c}^0$ ³⁾			6	9	12	$\geq N_{Rk,c}^0$ ³⁾						
Increasing factor for $N_{Rk,p} = N_{Rk,p}(C20/25) * \Psi_c$	Ψ_c [-]	$(f_{ck}/20)^{0,5}$													
Concrete cone and splitting failure															
Effective embedment depth	$h_{ef}^{2)}$ [mm]	30,6	47,6	56,1	40	46,4	54,9	42,5	59,5	68,0					
Factor for	Uncracked	$k_{ucr,N}$ [-]	11,0												
	Cracked	$k_{cr,N}$ [-]	7,7												
Concrete cone failure	Edge distance	$c_{cr,N}$ [mm]	1,5 h_{ef}												
	Spacing	$s_{cr,N}$ [mm]	3 h_{ef}												
Characteristic resistance		$N_{Rk,sp}^0$ [kN]	$N_{Rk,p}$												
Splitting failure	Edge distance	$c_{cr,sp}$ [mm]	1,5 h_{ef}		60	70	85	1,65 h_{ef}							
	Spacing	$s_{cr,sp}$ [mm]	3,0 h_{ef}		120	140	170	3,30 h_{ef}							
Installation factor	γ_{inst} [-]	1,0						1,2	1,0						

¹⁾ In absence of other national regulations.

²⁾ In case $h_{nom} > h_{nom1}$ and $< h_{nom3}$ the actual h_{ef} for concrete failure can be calculated according to Tables A5, A6 or A8

³⁾ $N_{Rk,c}^0$ according to EN 1992-4:2018

Hilti screw anchor HUS4

Annex C1

Performances

Essential characteristics under static and quasi-static load in concrete

Table C1 continued

Fastener size HUS4	Type	8			8			10		
		H(F), C			T-H(F), T-C			H(F), C, A(F)		
Nominal embedment depth	h_{nom} [mm]	40	60	70	50	60	70	55	75	85
Steel failure for shear load										
Characteristic resistance										
Characteristic resistance	$V^0_{Rk,s}$ [kN]	18,8		21,9	19,0		22,0	28,8		32,0
Partial factor	$\gamma_{Ms,V}^{1)}$ [-]	1,25			1,50			1,25		
Ductility factor	k_7 [-]				0,8					
Characteristic resistance	$M^0_{Rk,s}$ [Nm]	32			46			64		
Concrete pry-out failure										
Pry-out factor	k_8 [-]	1,0	2,0	1,0	2,0	1,0	2,0	1,0	2,0	1,0
Concrete edge failure										
Effective length of fastener	l_f [mm]	40	60	70	50	60	70	55	75	85
Outside diameter of fastener	d_{nom} [mm]	8			8			10		

¹⁾ In absence of other national regulations.

Hilti screw anchor HUS4

Performances

Essential characteristics under static and quasi-static load in concrete

Annex C2

Table C2: Essential characteristics under static and quasi-static load in concrete for HUS4 carbon steel size 10 to 14

Fastener size HUS4 Type	10 T-H(F), T-C			12 H(F)			14 H(F), A(F)					
	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$			
Nominal embedment depth h_{nom} [mm]	55	75	85	60	80	100	65	85	115			
Adjustment												
Total max. thickness of adjustment layers t_{adj} [mm]	-	10	10	10	10	10	10	10	10			
Max. number of adjustments n_a [-]	-	2	2	2	2	2	2	2	2			
Steel failure for tension load												
Characteristic resistance $N_{Rk,s}$ [kN]	62,2			79,0			101,5					
Partial factor $\gamma_{Ms,N}^{1)}$ [-]	1,4			1,5								
Pull-out failure												
Characteristic resistance in uncracked concrete C20/25 $N_{Rk,p,ucr}$ [kN]	12	20	32	$\geq N_{Rk,c}^0$ ³⁾								
Characteristic resistance in cracked concrete C20/25 $N_{Rk,p,cr}$ [kN]	9	15	19	10	$\geq N_{Rk,c}^0$ ³⁾							
Increasing factor for $N_{Rk,p} = N_{Rk,p}(C20/25) * \psi_c$ ψ_c [-]	$(f_{ck}/20)^{0,5}$											
Concrete cone and splitting failure												
Effective embedment depth $h_{\text{ef}}^{2)}$ [mm]	41,6	58,6	67,1	45,9	62,9	79,9	49,3	66,3	91,8			
Factor for	Uncracked $k_{ucr,N}$ [-]	11,0										
	Cracked $k_{cr,N}$ [-]	7,7										
Concrete cone failure	Edge distance $c_{cr,N}$ [mm]	1,5 h_{ef}										
	Spacing $s_{cr,N}$ [mm]	3 h_{ef}										
Characteristic resistance $N_{Rk,sp}^0$ [kN]	$N_{Rk,p}$											
Splitting failure	Edge distance $c_{cr,sp}$ [mm]	65	90	110	1,65 h_{ef}			1,60 h_{ef}				
	Spacing $s_{cr,sp}$ [mm]	130	180	220	3,30 h_{ef}			3,20 h_{ef}				
Installation factor γ_{inst} [-]	1,0											

¹⁾ In absence of other national regulations.

²⁾ In case $h_{\text{nom}} > h_{\text{nom}1}$ and $< h_{\text{nom}3}$ the actual h_{ef} for concrete failure can be calculated according to Tables A5, A6 or A8

³⁾ $N_{Rk,c}^0$ according to EN 1992-4:2018

Hilti screw anchor HUS4

Performances
Essential characteristics under static and quasi-static load in concrete

Annex C3

Table C2 continued

Fastener size HUS4		10			12			14					
Type		T-H(F), T-C			H(F)			H(F), A(F)					
		h_{nom1}	h_{nom2}	h_{nom3}	h_{nom1}	h_{nom2}	h_{nom3}	h_{nom1}	h_{nom2}	h_{nom3}			
Nominal embedment depth	h_{nom} [mm]	55	75	85	60	80	100	65	85	115			
Steel failure for shear load													
Characteristic resistance	$V^0_{Rk,s}$ [kN]	30		34	38,9		44,9	55		62			
Partial factor	$\gamma_{Ms,V}^{1)}$ [-]	1,50			1,25								
Ductility factor	k_7 [-]	0,8											
Characteristic resistance	$M^0_{Rk,s}$ [Nm]	92			120			186					
Concrete pry-out failure													
Pry-out factor	k_8 [-]	1,0	2,0		2,0								
Concrete edge failure													
Effective length of fastener	l_f [mm]	55	75	85	60	80	100	65	85	115			
Outside diameter of fastener	d_{nom} [mm]	10			12			14					

¹⁾ In absence of other national regulations.

Hilti screw anchor HUS4

Performances

Essential characteristics under static and quasi-static load in concrete

Annex C4

Table C3: Essential characteristics under static and quasi-static load in concrete for HUS4 carbon steel size 16

Fastener size HUS4		16	
Type	H(F)	h_{nom1}	h_{nom2}
Nominal embedment depth	h_{nom} [mm]	85	130
Adjustment			
Total max. thickness of adjustment layers	t_{adj} [mm]	-	-
Max. number of adjustments	n_a [-]	-	-
Steel failure for tension load			
Characteristic resistance	$N_{Rk,s}$ [kN]	107,7	
Partial factor	$\gamma_{Ms,N}^{1)}$ [-]	1,5	
Pull-out failure			
Characteristic resistance in uncracked concrete C20/25	$N_{Rk,p,ucr}$ [kN]	22	46
Characteristic resistance in cracked concrete C20/25	$N_{Rk,p,cr}$ [kN]	16	32
Increasing factor for $N_{Rk,p} = N_{Rk,p}(C20/25) * \psi_c$	ψ_c [-]	$(f_{ck}/20)^{0,5}$	
Concrete cone and splitting failure			
Effective embedment depth	$h_{ef}^{2)}$ [mm]	66,6	104,9
Factor for	Uncracked $k_{ucr,N}$ [-]	11,0	
	Cracked $k_{cr,N}$ [-]	7,7	
Concrete cone failure	Edge distance $c_{cr,N}$ [mm]	1,5 h_{ef}	
	Spacing $s_{cr,N}$ [mm]	3 h_{ef}	
Characteristic resistance	$N_{Rk,sp}^0$ [kN]	$N_{Rk,p}$	
Splitting failure	Edge distance $c_{cr,sp}$ [mm]	1,60 h_{ef}	
	Spacing $s_{cr,sp}$ [mm]	3,20 h_{ef}	
Installation factor	γ_{inst} [-]	1,0	

¹⁾ In absence of other national regulations.

²⁾ In case $h_{nom} > h_{nom1}$ and $< h_{nom2}$ the actual h_{ef} for concrete failure can be calculated according to Table A6

Hilti screw anchor HUS4

Performances
Essential characteristics under static and quasi-static load in concrete

Annex C5

Table C3 continued

Fastener size HUS4		16	
Type		H(F)	
		$h_{\text{nom}1}$	$h_{\text{nom}2}$
Nominal embedment depth	h_{nom} [mm]	85	130
Steel failure for shear load			
Characteristic resistance	$V^0_{Rk,s}$ [kN]	65,1	73,1
Partial factor	$\gamma_{Ms,V}^{1)}$ [-]	1,25	
Ductility factor	k_7 [-]	0,8	
Characteristic resistance	$M^0_{Rk,s}$ [Nm]	240	
Concrete pry-out failure			
Pry-out factor	k_8 [-]	2,0	
Concrete edge failure			
Effective length of fastener	l_f [mm]	85	130
Outside diameter of fastener	d_{nom} [mm]	16	

¹⁾ In absence of other national regulations.

Hilti screw anchor HUS4

Performances

Essential characteristics under static and quasi-static load in concrete

Annex C6

Table C4: Essential characteristics under static and quasi-static load in concrete for HUS4 stainless steel

Fastener size HUS4	6	8		10		14					
Type	HR, CR	HR, CR		HR, CR		HR					
Nominal embedment depth h_{nom} [mm]	55	60	80	70	90	70	110				
Steel failure for tension and shear load											
Characteristic resistance $N_{Rk,s}$ [kN]	24,0	34,0		52,6		102,2					
Partial factor $\gamma_{Ms,N}^{(1)}$ [-]	1,4										
Characteristic resistance $V_{Rk,s}$ [kN]	17,0	26,0		33,0		55,0	77,0				
Partial factor $\gamma_{Ms,V}^{(1)}$ [-]	1,5										
Ductility factor k_7 [-]	1,0										
Characteristic resistance $M^0_{Rk,s}$ [Nm]	19	36		66		193					
Pull-out failure											
Characteristic resistance in cracked concrete C20/25 $N_{Rk,p,cr}$ [kN]	5	8,5	15	12	16	12	25				
Characteristic resistance in uncracked concrete C20/25 $N_{Rk,p,ucr}$ [kN]	9	12	16	16	25	$\geq N^0_{Rk,c}^{(3)}$					
Increasing factor for $N_{Rk,p} = N_{Rk,p(C20/25)} * \psi_c$ ψ_c [-]	$(f_{ck}/20)^{0,5}$										
Concrete cone and splitting failure											
Effective anchorage depth $h_{\text{ef}}^{(2)}$ [mm]	45	47	64	54	71	52	86				
Factor for	Cracked $k_{cr,N}$ [-]	7,7									
	Uncracked $k_{ucr,N}$ [-]	11,0									
Concrete cone failure	Edge distance $c_{cr,N}$ [mm]	1,5 h_{ef}									
	Spacing $s_{cr,N}$ [mm]	3 h_{ef}									
Splitting failure	Edge distance $c_{cr,sp}$ [mm]	1,5 h_{ef}	1,5 h_{ef}		1,8 h_{ef}		1,8 h_{ef}				
	Spacing $s_{cr,sp}$ [mm]	3 h_{ef}	3 h_{ef}		3,6 h_{ef}		3,6 h_{ef}				
Robustness γ_{inst} [-]	1,4	1,0	1,2	1,2	1,0	1,2					
Concrete pry-out failure											
Pry-out factor k_8 [mm]	1,5	2,0									
Concrete edge failure											
Effective length of anchor l_f [mm]	55	60	80	70	90	70	110				
Effective diameter of anchor d_{nom} [mm]	6	8		10		14					

¹⁾ In absence of other national regulations.

²⁾ In case $h_{\text{nom}} > h_{\text{nom}1}$ and $< h_{\text{nom}2}$ the actual h_{ef} for concrete failure can be calculated according to Tables A7 or A8

³⁾ $N^0_{Rk,c}$ according to EN 1992-4:2018

Hilti screw anchor HUS4

Performances
Essential characteristics under static and quasi-static load in concrete

Annex C7

Table C5: Essential characteristics for seismic performance category C1 in concrete for HUS4 carbon steel size 8 to 10

Fastener size HUS4	8		8			10				
Type	H(F), C		T-H(F), T-C			H(F), C, A(F)				
	h_{nom2}	h_{nom3}	h_{nom1}	h_{nom2}	h_{nom3}	h_{nom1}	h_{nom2}	h_{nom3}		
Nominal embedment depth	h_{nom}	[mm]	60	70	50	60	70	55	75	85
Adjustment										
Total max. thickness of adjustment layers	t_{adj}	[mm]	10	10	-	10	10	-	10	10
Max. number of adjustments	n_a	[-]	2	2	-	2	2	-	2	2
Steel failure for tension and shear load										
Characteristic resistance	$N_{Rk,s,C1}$	[kN]	36,0		39,2		55,0			
Partial factor	$\gamma_{Ms,N}^{1)}$	[-]	1,5		1,4		1,5			
Characteristic resistance	$V_{Rk,s,C1}$	[kN]	18,8		16,5		26,1	26,7		
Partial factor	$\gamma_{Ms,V}^{1)}$	[-]	1,25		1,5		1,25			
Reduction factor acc. to EN 1992-4:2018 annular gap unfilled	α_{gap}	[-]	0,5							
Reduction factor acc. to EN 1992-4:2018 annular gap filled	α_{gap}	[-]	1,0							
Pull-out failure										
Characteristic resistance in cracked concrete	$N_{Rk,p,C1}$	[kN]	$\geq N_{Rk,c}^0$ ³⁾		6	9	12	$\geq N_{Rk,c}^0$ ³⁾		
Concrete cone failure										
Effective embedment depth	$h_{ef}^{2)}$	[mm]	47,6	56,1	40	46,4	54,9	42,5	59,5	68,0
Concrete cone failure	Edge distance	$c_{cr,N}$	1,5 h_{ef}							
	Spacing	$s_{cr,N}$	3 h_{ef}							
Installation factor	γ_{inst}	[-]	1,0				1,2	1,0		
Concrete pry-out failure										
Pry-out factor	k_8	[-]	2,0		1,0	2,0		1,0	2,0	
Concrete edge failure										
Effective length of fastener	l_f	[mm]	60	70	50	60	70	55	75	85
Outside diameter of fastener	d_{nom}	[mm]	8		8		10			

¹⁾ In absence of other national regulations.

²⁾ In case $h_{nom} > h_{nom1}$ and $< h_{nom3}$ the actual h_{ef} for concrete failure can be calculated according to Tables A5, A6 or A8

³⁾ $N_{Rk,c}^0$ according to EN 1992-4:2018

Hilti screw anchor HUS4

Performances
Essential characteristics for seismic performance category C1 in concrete

Annex C8

Table C6: Essential characteristics for seismic performance category C1 in concrete for HUS4 carbon steel size 10 to 14

Fastener size HUS4 Type	10 T-H(F), T-C			12 H(F)			14 H(F), A(F)								
	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$						
Nominal embedment depth h_{nom} [mm]	55	75	85	60	80	100	65	85	115						
Adjustment															
Total max. thickness of adjustment layers t_{adj} [mm]	-	10	10	10	10	10	10	10	10						
Max. number of adjustments n_a [-]	-	2	2	2	2	2	2	2	2						
Steel failure for tension and shear load															
Characteristic resistance $N_{Rk,s,C1}$ [kN]	62,2			79,0			101,5								
Partial factor $\gamma_{Ms,N}^{1)}$ [-]	1,5														
Characteristic resistance $V_{Rk,s,C1}$ [kN]	25,7			33,2			38,9								
Partial factor $\gamma_{Ms,V}^{1)}$ [-]	1,5			1,25											
Reduction factor acc. to EN 1992-4:2018 annular gap unfilled α_{gap} [-]	0,5														
Reduction factor acc. to EN 1992-4:2018 annular gap filled α_{gap} [-]	1,0														
Pull-out failure															
Characteristic resistance in cracked concrete $N_{Rk,p,C1}$ [kN]	9	15	19	$\geq N^0_{Rk,c} {}^3)$											
Concrete cone failure															
Effective embedment depth $h_{\text{ef}}^{2)}$ [mm]	41,6	58,6	67,1	45,9	62,9	79,9	49,3	66,3	91,8						
Concrete cone failure Edge distance $c_{\text{cr},N}$ [mm]	1,5 h_{ef}														
Concrete cone failure Spacing $s_{\text{cr},N}$ [mm]	3 h_{ef}														
Installation factor γ_{inst} [-]	1,0														
Concrete pry-out failure															
Pry-out factor k_8 [-]	1,0	2,0			2,0										
Concrete edge failure															
Effective length of fastener l_f [mm]	55	75	85	60	80	100	65	85	115						
Outside diameter of fastener d_{nom} [mm]	10			12			14								

¹⁾ In absence of other national regulations.

²⁾ In case $h_{\text{nom}} > h_{\text{nom}1}$ and $< h_{\text{nom}3}$ the actual h_{ef} for concrete failure can be calculated according to Tables A5, A6 or A8

³⁾ $N^0_{Rk,c}$ according to EN 1992-4:2018

Hilti screw anchor HUS4

Performances
Essential characteristics for seismic performance category C1 in concrete

Annex C9

Table C7: Essential characteristics for seismic performance category C1 in concrete for HUS4 carbon steel size 16

Fastener size HUS4		16	
Type		H(F)	
		$h_{\text{nom}1}$	$h_{\text{nom}2}$
Nominal embedment depth	h_{nom} [mm]	85	130
Steel failure for tension and shear load			
Characteristic resistance	$N_{Rk,s,C1}$ [kN]	107,7	
Partial factor	$\gamma_{Ms,N}^{1)}$ [-]	1,5	
Characteristic resistance	$V_{Rk,s,C1}$ [kN]	42,9	25,3
Partial factor	$\gamma_{Ms,V}^{1)}$ [-]	1,25	
Reduction factor acc. to EN 1992-4:2018 annular gap unfilled	α_{gap} [-]	0,5	
Reduction factor acc. to EN 1992-4:2018 annular gap filled	α_{gap} [-]	1,0	
Pull-out failure			
Characteristic resistance in cracked concrete	$N_{Rk,p,C1}$ [kN]	7,5	19,0
Concrete cone failure			
Effective embedment depth	$h_{\text{ef}}^{2)}$ [mm]	66,6	104,9
Concrete cone failure	Edge distance $c_{\text{cr},N}$ [mm]	1,5 h_{ef}	
	Spacing $s_{\text{cr},N}$ [mm]	3 h_{ef}	
Installation factor	γ_{inst} [-]	1,0	
Concrete pry-out failure			
Pry-out factor	k_8 [-]	2,0	
Concrete edge failure			
Effective length of fastener	l_f [mm]	85	130
Outside diameter of fastener	d_{nom} [mm]	16	

¹⁾ In absence of other national regulations.

²⁾ In case $h_{\text{nom}} > h_{\text{nom}1}$ and $< h_{\text{nom}2}$ the actual h_{ef} for concrete failure can be calculated according to Table A6

Hilti screw anchor HUS4

Performances
Essential characteristics for seismic performance category C1 in concrete

Annex C10

Table C8: Essential characteristics for seismic performance category C1 in concrete for HUS4 stainless steel

Fastener size HUS4	8	10	14
Type	HR, CR	HR, CR	HR
Nominal embedment depth h_{nom} [mm]	h_{nom2}	h_{nom2}	h_{nom2}
Nominal embedment depth h_{nom} [mm]	80	90	110
Steel failure for tension and shear load			
Characteristic resistance $N_{Rk,s,C1}$ [kN]	34,0	52,6	102,2
Partial factor $\gamma_{Ms,N}^{1)}$ [-]		1,4	
Characteristic resistance $V_{Rk,s,C1}$ [kN]	11,1	17,9	53,9
Partial factor $\gamma_{Ms,V}^{1)}$ [-]		1,5	
Pull-out failure			
Characteristic resistance in cracked concrete $N_{Rk,p,C1}$ [kN]	7,7	12,5	17,5
Concrete cone failure			
Effective embedment depth h_{ef} [mm]	64	71	86
Concrete cone failure Edge distance $c_{cr,N}$ [mm]		1,5 h_{ef}	
Concrete cone failure Spacing $s_{cr,N}$ [mm]		3 h_{ef}	
Robustness γ_{inst} [-]	1,2	1,0	1,2
Concrete pry-out failure			
Pry-out factor k_8 [-]		2,0	
Concrete edge failure			
Effective length of fastener $l_f = h_{\text{ef}}$ [mm]	64	71	86
Outside diameter of fastener d_{nom} [mm]	8	10	14

¹⁾ In absence of other national regulations.

Hilti screw anchor HUS4

Performances

Essential characteristics for seismic performance category C1 in concrete

Annex C11

Table C9: Essential characteristics for seismic performance category C2 in concrete for HUS4 carbon steel size 8 to 10

Fastener size HUS4 Type	8 H(F), C		8 T-H(F), T-C			10 H(F), C, A(F)		
	$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$
Nominal embedment depth h_{nom} [mm]	60	70	50	60	70	55	75	85
Adjustment								
Total max. thickness of adjustment layers t_{adj} [mm]	10	10	-	10	10	-	10	10
Max. number of adjustments n_a [-]	2	2	-	2	2	-	2	2
Steel failure for tension								
Characteristic resistance $N_{Rk,s,C2}$ [kN]	36,0		39,2			55,0		
Partial factor $\gamma_{Ms,N}^{1)}$ [-]	1,5		1,4			1,5		
Steel failure for shear load								
Partial factor $\gamma_{Ms,V}^{1)}$ [-]	1,25		1,5			1,25		
Installation with Hilti filling set (HUS4-H and HUS4-A)								
Characteristic resistance $V_{Rk,s,C2}$ [kN]	8,7	16,0	9,2	14,7	15,1	23,2		
Partial factor annular gap filled α_{gap} [-]	1,0							
Installation without Hilti filling set								
Characteristic resistance $V_{Rk,s,C2}$ [kN]	8,7	10,8	9,2	10,8	14,8			
Partial factor annular gap not filled α_{gap} [-]	0,5							
Pull-out failure								
Characteristic resistance in cracked concrete $N_{Rk,p,C2}$ [kN]	1,8	2,7	2,3	2,8	3,2	2,6	3,6	5,4
Concrete cone failure								
Effective embedment depth $h_{\text{ef}}^{2)}$ [mm]	47,6	56,1	40	46,4	54,9	42,5	59,5	68,0
Concrete cone failure Edge distance $c_{\text{cr},N}$ [mm]	1,5 h_{ef}							
Spacing $s_{\text{cr},N}$ [mm]	3 h_{ef}							
Installation factor γ_{inst} [-]	1,0				1,2		1,0	
Concrete pry-out failure								
Pry-out factor k_8 [-]	2,0	1,0	2,0	1,0	2,0	1,0	2,0	
Concrete edge failure								
Effective length of fastener l_f [mm]	60	70	50	60	70	55	75	85
Outside diameter of fastener d_{nom} [mm]	8		8			10		

¹⁾ In absence of other national regulations.

²⁾ In case $h_{\text{nom}} > h_{\text{nom}1}$ and $< h_{\text{nom}3}$ the actual h_{ef} for concrete failure can be calculated according to Tables A5, A6 or A8

Hilti screw anchor HUS4

Annex C12

Performances

Essential characteristics for seismic performance category C2 in concrete

Table C10: Essential characteristics for seismic performance category C2 in concrete for HUS4 carbon steel size 10 to 14

Fastener size HUS4 Type	10 T-H(F), T-C			12 H(F)			14 H(F), A(F)				
	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$		
Nominal embedment depth h_{nom} [mm]	55	75	85	60	80	100	65	85	115		
Adjustment											
Total max. thickness of adjustment layers t_{adj} [mm]	-	10	10	10	10	10	10	10	10		
Max. number of adjustments n_a [-]	-	2	2	2	2	2	2	2	2		
Steel failure for tension											
Characteristic resistance $N_{Rk,s,C2}$ [kN]	62,2			79,0			101,5				
Partial factor $\gamma_{Ms,N}^{1)}$ [-]	1,4			1,5							
Steel failure for shear load											
Partial factor $\gamma_{Ms,V}^{1)}$ [-]	1,5			1,25							
Installation with Hilti filling set (HUS4-H and HUS4-A)											
Characteristic resistance $V_{Rk,s,C2}$ [kN]	13,3		25,6	20,0	28,6	29,2	46,5				
Partial factor annular gap filled α_{gap} [-]	1,0										
Installation without Hilti filling set											
Characteristic resistance $V_{Rk,s,C2}$ [kN]	13,3		17,7	20,0	23,7	29,2	34,4				
Partial factor annular gap not filled α_{gap} [-]	0,5										
Pull-out failure											
Characteristic resistance in cracked concrete $N_{Rk,p,C2}$ [kN]	2,8	5,4	6,4	5,7	8,5	11,4	5,4	8,9	17,7		
Concrete cone failure											
Effective embedment depth $h_{\text{ef}}^{2)}$ [mm]	41,6	58,6	67,1	45,9	62,9	79,9	49,3	66,3	91,8		
Concrete cone failure Edge distance $c_{\text{cr},N}$ [mm]				1,5 h_{ef}							
Spacing $s_{\text{cr},N}$ [mm]				3 h_{ef}							
Installation factor γ_{inst} [-]	1,0										
Concrete pry-out failure											
Pry-out factor k_8 [-]	1,0	2,0		2,0							
Concrete edge failure											
Effective length of fastener l_f [mm]	55	75	85	60	80	100	65	85	115		
Outside diameter of fastener d_{nom} [mm]	10			12			14				

¹⁾ In absence of other national regulations.

²⁾ In case $h_{\text{nom}} > h_{\text{nom}1}$ and $< h_{\text{nom}3}$ the actual h_{ef} for concrete failure can be calculated according to Tables A5, A6 or A8

Hilti screw anchor HUS4

Annex C13

Performances
Essential characteristics for seismic performance category C2 in concrete

Table C11: Essential characteristics under fire exposure in concrete for HUS4 (T)-H carbon steel sizes 8 and 10

Fastener size HUS4 (T)-H(F)		8			T-8			10											
Nominal embedment depth	h_{nom} [mm]	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$									
Adjustment																			
Total max. thickness of adjustment layers	t_{adj} [mm]	-	10	10	-	10	10	-	10	10									
Max. number of adjustments	n_a [-]	-	2	2	-	2	2	-	2	2									
Steel failure for tension and shear load ($F_{Rk,s,fi} = N_{Rk,s,fi} = V_{Rk,s,fi}$)																			
Characteristic resistance	R30	$F_{Rk,s,fi}$ [kN]	2,6		3,2	3,5	3,8	4,1	4,2										
	R60	$F_{Rk,s,fi}$ [kN]	1,9		2,4	2,6	2,8	3,1	3,1										
	R90	$F_{Rk,s,fi}$ [kN]	1,2		1,6	1,6	1,9	2,2	2,3										
	R120	$F_{Rk,s,fi}$ [kN]	0,9		1,2	1,2	1,5	1,5	1,7										
	R30	$M^0_{Rk,s,fi}$ [Nm]	2,3		3,8	4,1	4,4	4,8	4,9										
	R60	$M^0_{Rk,s,fi}$ [Nm]	1,7		2,8	3,0	3,4	3,6	3,7										
	R90	$M^0_{Rk,s,fi}$ [Nm]	1,1		1,9	1,9	2,3	2,6	2,7										
	R120	$M^0_{Rk,s,fi}$ [Nm]	0,8		1,5	1,4	1,7	1,8	1,9										
Pull-out failure																			
Characteristic resistance	R30	$N^0_{Rk,p,fi}$ [kN]	1,3	2,8	3,6	1,5	2,3	3,0	2,3	3,9									
	R60	$N^0_{Rk,p,fi}$ [kN]	1,0	2,2	2,8	1,2	1,8	2,4	1,9	3,1									
	R90	$N^0_{Rk,p,fi}$ [kN]	0,8	2,6	4,0	1,8	2,6	4,0	2,0	4,7									
	R120	$N^0_{Rk,p,fi}$ [kN]	0,7	2,1	3,2	1,4	2,1	3,2	1,6	3,7									
Concrete cone failure																			
Characteristic resistance	R30	$N^0_{Rk,c,fi}$ [kN]	0,8	2,6	4,0	1,8	2,6	4,0	2,0	4,7									
	R60	$N^0_{Rk,c,fi}$ [kN]	0,7	2,1	3,2	1,4	2,1	3,2	1,6	3,7									
	R90	$N^0_{Rk,c,fi}$ [kN]	0,7	2,1	3,2	1,4	2,1	3,2	1,6	3,7									
	R120	$N^0_{Rk,c,fi}$ [kN]	0,7	2,1	3,2	1,4	2,1	3,2	1,6	3,7									
Edge distance																			
R30 to R120	$c_{cr,fi}$ [mm]	2 h_{ef}																	
In case of fire attack from more than one side, the minimum edge distance shall be ≥ 300 mm																			
Fastener spacing																			
R30 to R120	$s_{cr,fi}$ [mm]	2 $c_{cr,fi}$																	
Concrete pry-out failure																			
R30 to R120	k_8 [-]	1,0	2,0	1,0	2,0	1,0	2,0	1,0	2,0										
The anchorage depth shall be increased for wet concrete by at least 30 mm compared to the given value																			
Hilti screw anchor HUS4								Annex C14											
Performances Essential characteristics under fire exposure in concrete																			

Table C12: Essential characteristics under fire exposure in concrete for HUS4 (T)-H carbon steel sizes 10 to 14

Fastener size HUS4 (T)-H(F)		T-10			12			14											
		h_{nom1}	h_{nom2}	h_{nom3}	h_{nom1}	h_{nom2}	h_{nom3}	h_{nom1}	h_{nom2}	h_{nom3}									
Nominal embedment depth	h_{nom} [mm]	55	75	85	60	80	100	65	85	115									
Adjustment																			
Total max. thickness of adjustment layers	t_{adj} [mm]	-	10	10	10	10	10	10	10	10									
Max. number of adjustments	n_a [-]	-	2	2	2	2	2	2	2	2									
Steel failure for tension and shear load ($F_{Rk,s,fi} = N_{Rk,s,fi} = V_{Rk,s,fi}$)																			
Characteristic resistance	R30	$F_{Rk,s,fi}$ [kN]	6,1	6,2	7,5	7,6	7,6	10,3	10,4	10,5									
	R60	$F_{Rk,s,fi}$ [kN]	4,6	4,7	5,5	5,7	5,8	7,7	7,9	8,0									
	R90	$F_{Rk,s,fi}$ [kN]	3,1	3,2	3,7	3,9	4,1	5,2	5,6	5,8									
	R120	$F_{Rk,s,fi}$ [kN]	2,4	2,5	2,8	3,0	3,1	3,9	4,2	4,4									
	R30	$M^0_{Rk,s,fi}$ [Nm]	9,1	9,2	11,4	11,6	11,6	18,9	19,2	19,3									
	R60	$M^0_{Rk,s,fi}$ [Nm]	6,9	7,0	8,4	8,8	8,9	14,1	14,6	14,8									
	R90	$M^0_{Rk,s,fi}$ [Nm]	4,6	4,8	5,7	6,0	6,2	9,5	10,2	10,7									
	R120	$M^0_{Rk,s,fi}$ [Nm]	3,5	3,7	4,3	4,6	4,7	7,2	7,7	8,1									
Pull-out failure																			
Characteristic resistance	R30	$N^0_{Rk,p,fi}$ [kN]	2,4	4,0	4,9	2,6	4,2	6,1	2,9	4,5									
	R60	$N^0_{Rk,p,fi}$ [kN]	1,9	3,2	3,9	2,1	3,4	4,9	2,3	3,6									
	R90	$N^0_{Rk,p,fi}$ [kN]	2,4	4,0	4,9	2,6	4,2	6,1	2,9	4,5									
	R120	$N^0_{Rk,p,fi}$ [kN]	1,9	3,2	3,9	2,1	3,4	4,9	2,3	3,6									
Concrete cone failure																			
Characteristic resistance	R30	$N^0_{Rk,c,fi}$ [kN]	2,0	4,7	6,6	2,4	5,4	9,8	2,9	6,1									
	R60	$N^0_{Rk,c,fi}$ [kN]	1,6	3,8	5,3	1,9	4,3	7,8	2,3	4,9									
	R90	$N^0_{Rk,c,fi}$ [kN]	2,0	4,7	6,6	2,4	5,4	9,8	2,9	6,1									
Edge distance																			
R30 to R120	$c_{cr,fi}$ [mm]	2 h_{ef}																	
In case of fire attack from more than one side, the minimum edge distance shall be ≥ 300 mm																			
Fastener spacing																			
R30 to R120	$s_{cr,fi}$ [mm]	2 $c_{cr,fi}$																	
Concrete pry-out failure																			
R30 to R120	k_8 [-]	1,0	2,0	2,0															
The anchorage depth shall be increased for wet concrete by at least 30 mm compared to the given value																			

Hilti screw anchor HUS4

Performances
Essential characteristics under fire exposure in concrete

Annex C15

Table C13: Essential characteristics under fire exposure in concrete for HUS4-H carbon steel size 16

Fastener size HUS4-H(F)		16			
		h_{nom1}	h_{nom2}		
Nominal embedment depth	h_{nom} [mm]	85	130		
Steel failure for tension and shear load ($F_{Rk,s,fi} = N_{Rk,s,fi} = V_{Rk,s,fi}$)					
Characteristic resistance	R30	$F_{Rk,s,fi}$ [kN]	10,6		
	R60	$F_{Rk,s,fi}$ [kN]	8,1		
	R90	$F_{Rk,s,fi}$ [kN]	5,7		
	R120	$F_{Rk,s,fi}$ [kN]	4,3		
	R30	$M^0_{Rk,s,fi}$ [Nm]	23,7		
	R60	$M^0_{Rk,s,fi}$ [Nm]	18,1		
	R90	$M^0_{Rk,s,fi}$ [Nm]	12,7		
	R120	$M^0_{Rk,s,fi}$ [Nm]	9,6		
Pull-out failure					
Characteristic resistance	R30				
	R60	$N^0_{Rk,p,fi}$ [kN]	4,6		
	R90		8,7		
	R120	$N^0_{Rk,p,fi}$ [kN]	3,7		
Concrete cone failure					
Characteristic resistance	R30				
	R60	$N^0_{Rk,c,fi}$ [kN]	6,2		
	R90		19,4		
	R120	$N^0_{Rk,c,fi}$ [kN]	4,9		
Edge distance					
R30 to R120	$c_{cr,fi}$ [mm]	2 h_{ef}			
In case of fire attack from more than one side, the minimum edge distance shall be ≥ 300 mm					
Fastener spacing					
R30 to R120	$s_{cr,fi}$ [mm]	2 $c_{cr,fi}$			
Concrete pry-out failure					
R30 to R120	k_8 [-]	2,0			
The anchorage depth shall be increased for wet concrete by at least 30 mm compared to the given value					

Hilti screw anchor HUS4

Performances
Essential characteristics under fire exposure in concrete

Annex C16

Table C14: Essential characteristics under fire exposure in concrete for HUS4 (T)-C carbon steel size 8

Fastener size HUS4 (T)-C		8			T-8							
Nominal embedment depth	h_{nom} [mm]	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$					
Adjustment												
Total max. thickness of adjustment layers	t_{adj} [mm]	-	10	10	-	10	10					
Max. number of adjustments												
Steel failure for tension and shear load ($F_{Rk,s,fi} = N_{Rk,s,fi} = V_{Rk,s,fi}$)												
Characteristic resistance	R30	$F_{Rk,s,fi}$ [kN]	0,5		0,5							
	R60	$F_{Rk,s,fi}$ [kN]	0,4		0,4							
	R90	$F_{Rk,s,fi}$ [kN]	0,3		0,3							
	R120	$F_{Rk,s,fi}$ [kN]	0,2		0,2							
	R30	$M^0_{Rk,s,fi}$ [Nm]	0,4		0,6							
	R60	$M^0_{Rk,s,fi}$ [Nm]	0,3		0,5							
	R90	$M^0_{Rk,s,fi}$ [Nm]	0,2		0,4							
	R120	$M^0_{Rk,s,fi}$ [Nm]	0,2		0,3							
Pull-out failure												
Characteristic resistance	R30											
	R60	$N^0_{Rk,p,fi}$ [kN]	1,3	2,8	3,6	1,5	2,3					
	R90											
	R120	$N^0_{Rk,p,fi}$ [kN]	1,0	2,2	2,8	1,2	1,8					
Concrete cone failure												
Characteristic resistance	R30											
	R60	$N^0_{Rk,c,fi}$ [kN]	0,8	2,6	4,0	1,8	2,6					
	R90											
	R120	$N^0_{Rk,c,fi}$ [kN]	0,7	2,1	3,2	1,5	2,1					
Edge distance												
R30 to R120		$c_{cr,fi}$ [mm]	2 h_{ef}									
In case of fire attack from more than one side, the minimum edge distance shall be ≥ 300 mm												
Fastener spacing												
R30 to R120		$s_{cr,fi}$ [mm]	2 $c_{cr,fi}$									
Concrete pry-out failure												
R30 to R120		k_8 [-]	1,0	2,0	1,0	2,0						
The anchorage depth shall be increased for wet concrete by at least 30 mm compared to the given value												

Hilti screw anchor HUS4

Performances
Essential characteristics under fire exposure in concrete

Annex C17

Table C15: Essential characteristics under fire exposure in concrete for HUS4 (T)-C carbon steel size 10

Fastener size HUS4 (T)-C		10			T-10							
Nominal embedment depth	h_{nom} [mm]	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$					
Adjustment												
Total max. thickness of adjustment layers	t_{adj} [mm]	-	10	10	-	10	10					
Max. number of adjustments												
Steel failure for tension and shear load ($F_{Rk,s,fi} = N_{Rk,s,fi} = V_{Rk,s,fi}$)												
Characteristic resistance	R30	$F_{Rk,s,fi}$ [kN]	1,0		1,2							
	R60	$F_{Rk,s,fi}$ [kN]	0,9		1,0							
	R90	$F_{Rk,s,fi}$ [kN]	0,7		0,8							
	R120	$F_{Rk,s,fi}$ [kN]	0,6		0,6							
	R30	$M^0_{Rk,s,fi}$ [Nm]	1,2		1,7							
	R60	$M^0_{Rk,s,fi}$ [Nm]	1,0		1,5							
	R90	$M^0_{Rk,s,fi}$ [Nm]	0,8		1,1							
	R120	$M^0_{Rk,s,fi}$ [Nm]	0,6		0,9							
Pull-out failure												
Characteristic resistance	R30	$N^0_{Rk,p,fi}$ [kN]	2,3	3,9	4,7	2,4	4,0					
	R60	$N^0_{Rk,p,fi}$ [kN]	1,9	3,1	3,7	1,9	3,2					
	R90	$N^0_{Rk,p,fi}$ [kN]	1,6	3,7	5,2	1,6	3,8					
	R120	$N^0_{Rk,p,fi}$ [kN]	1,6	3,7	5,2	1,6	3,8					
Concrete cone failure												
Characteristic resistance	R30	$N^0_{Rk,c,fi}$ [kN]	2,0	4,7	6,5	2,0	4,7					
	R60	$N^0_{Rk,c,fi}$ [kN]	1,6	3,7	5,2	1,6	3,8					
	R90	$N^0_{Rk,c,fi}$ [kN]	1,6	3,7	5,2	1,6	3,8					
	R120	$N^0_{Rk,c,fi}$ [kN]	1,6	3,7	5,2	1,6	3,8					
Edge distance												
R30 to R120		$c_{cr,fi}$ [mm]	2 h_{ef}									
In case of fire attack from more than one side, the minimum edge distance shall be ≥ 300 mm												
Fastener spacing												
R30 to R120		$s_{cr,fi}$ [mm]	2 $c_{cr,fi}$									
Concrete pry-out failure												
R30 to R120		k_8 [-]	1,0	2,0	1,0	2,0						
The anchorage depth shall be increased for wet concrete by at least 30 mm compared to the given value												

Hilti screw anchor HUS4

Performances
Essential characteristics under fire exposure in concrete

Annex C18

Table C16: Essential characteristics under fire exposure in concrete for HUS4-A carbon steel

Fastener size HUS4-A(F)		10			14								
Nominal embedment depth	h_{nom} [mm]	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}3}$						
Adjustment													
Total max. thickness of adjustment layers	t_{adj} [mm]	-	10	10	10	10	10						
Max. number of adjustments													
Steel failure for tension and shear load ($F_{Rk,s,fi} = N_{Rk,s,fi} = V_{Rk,s,fi}$)													
Characteristic resistance	R30	$F_{Rk,s,fi}$ [kN]	4,2		8,4								
	R60	$F_{Rk,s,fi}$ [kN]	3,3		6,8								
	R90	$F_{Rk,s,fi}$ [kN]	2,5		5,1								
	R120	$F_{Rk,s,fi}$ [kN]	2,1		4,3								
	R30	$M^0_{Rk,s,fi}$ [Nm]	4,8		15,4								
	R60	$M^0_{Rk,s,fi}$ [Nm]	3,8		12,4								
	R90	$M^0_{Rk,s,fi}$ [Nm]	2,9		9,3								
	R120	$M^0_{Rk,s,fi}$ [Nm]	2,4		7,8								
Pull-out failure													
Characteristic resistance	R30	$N^0_{Rk,p,fi}$ [kN]	2,3	3,9	4,7	2,9	4,5						
	R60	$N^0_{Rk,p,fi}$ [kN]	1,9	3,1	3,7	2,3	3,6						
	R90	$N^0_{Rk,p,fi}$ [kN]	1,9	3,1	3,7	2,3	3,6						
	R120	$N^0_{Rk,p,fi}$ [kN]	1,9	3,1	3,7	2,3	3,6						
Concrete cone failure													
Characteristic resistance	R30	$N^0_{Rk,c,fi}$ [kN]	2,0	4,7	6,5	2,9	6,1						
	R60	$N^0_{Rk,c,fi}$ [kN]	1,6	3,7	5,2	2,3	4,9						
	R90	$N^0_{Rk,c,fi}$ [kN]	1,6	3,7	5,2	2,3	4,9						
	R120	$N^0_{Rk,c,fi}$ [kN]	1,6	3,7	5,2	2,3	4,9						
Edge distance													
R30 to R120	$c_{cr,fi}$ [mm]	$2 h_{ef}$											
In case of fire attack from more than one side, the minimum edge distance shall be ≥ 300 mm													
Fastener spacing													
R30 to R120	$s_{cr,fi}$ [mm]	$2 c_{cr,fi}$											
Concrete pry-out failure													
R30 to R120	k_8 [-]	1,0	2,0										
The anchorage depth shall be increased for wet concrete by at least 30 mm compared to the given value													
Hilti screw anchor HUS4													
Performances Essential characteristics under fire exposure in concrete													
Annex C19													

Table C17: Essential characteristics under fire exposure in concrete for HUS4 stainless steel

Fastener size HUS4		6		8		10		14							
Type		HR	CR	HR	CR	HR	CR	HR							
		$h_{\text{nom}1}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}1}$	$h_{\text{nom}2}$	$h_{\text{nom}1}$						
Nominal embedment depth	h_{nom} [mm]	55	60	80	60	80	70	90	70						
Steel failure for tension and shear load ($F_{Rk,s,fi} = N_{Rk,s,fi} = V_{Rk,s,fi}$)															
Characteristic resistance	R30	$F_{Rk,s,fi}$ [kN]	4,9	0,2	9,3	0,8	18,5	1,4	41,7						
	R60	$F_{Rk,s,fi}$ [kN]	3,3	0,2	6,3	0,6	12,0	1,1	26,9						
	R90	$F_{Rk,s,fi}$ [kN]	1,8	0,2	3,2	0,5	5,4	0,9	12,2						
	R120	$F_{Rk,s,fi}$ [kN]	1,0	0,1	1,7	0,4	2,4	0,8	5,4						
	R30	$M^0_{Rk,s,fi}$ [Nm]	4,0	0,2	8,2	0,8	19,4	1,5	65,6						
	R60	$M^0_{Rk,s,fi}$ [Nm]	2,7	0,2	5,5	0,7	12,6	1,2	42,4						
	R90	$M^0_{Rk,s,fi}$ [Nm]	1,4	0,1	2,8	0,5	5,7	0,9	19,2						
	R120	$M^0_{Rk,s,fi}$ [Nm]	0,8	0,1	1,5	0,4	2,5	0,8	8,5						
Concrete pull-out failure															
Characteristic resistance	R30	$N_{Rk,p,fi}$ [kN]			1,3	1,5	3,0	1,5	3,0						
	R60	$N_{Rk,p,fi}$ [kN]				2,3	4,0	2,3	4,0						
	R90	$N_{Rk,p,fi}$ [kN]				3,0	6,3								
	R120	$N_{Rk,p,fi}$ [kN]			1,0	1,2	2,4	1,2	2,4						
Edge distance															
R30 to R120		$c_{cr,fi}$ [mm]	2 h_{ref}												
Anchor spacing															
R30 to R120		$s_{cr,fi}$ [mm]	2 $c_{cr,fi}$												
Concrete pry-out failure															
R30 to R120		k_8 [-]	1,5	2,0											
Hilti screw anchor HUS4															
Performances Essential characteristics under fire exposure in concrete															
Annex C20															

Table C18: Displacements under tension loads for HUS4 carbon steel

Fastener size HUS4			8			8			10		
Type			H(F), C			T-H(F), T-C			H(F), C, A(F)		
			h_{nom}	h_{nom2}	h_{nom3}	h_{nom}	h_{nom2}	h_{nom3}	h_{nom}	h_{nom2}	h_{nom3}
Nominal embedment depth	h_{nom}	[mm]	40	60	70	50	60	70	55	75	85
Cracked concrete C20/25 to C50/60	Tension Load N	[kN]	2,6	5,4	6,9	4,3	5,7	7,6	3,8	7,5	8,6
	Displacement δ_{N0}	[mm]	0,1	0,3	0,4	0,3	0,4	0,3	0,2	0,4	0,4
		[mm]	0,3	0,4	0,4	0,7	0,7	0,6	0,7	0,7	0,9
Uncracked concrete C20/25 to C50/60	Tension Load N	[kN]	3,7	7,1	9,1	6,6	8,9	11,8	5,2	10,5	12,2
	Displacement δ_{N0}	[mm]	0,1	0,2	0,2	0,1	0,2	0,1	0,1	0,3	0,3
		[mm]	0,3	0,4	0,4	0,3	0,3	0,3	0,7	0,7	0,9

Fastener size HUS4			10			12			14		
Type			T-H(F), T-C			H			H(F), A(F)		
			h_{nom1}	h_{nom2}	h_{nom3}	h_{nom1}	h_{nom2}	h_{nom3}	h_{nom1}	h_{nom2}	h_{nom3}
Nominal embedment depth	h_{nom}	[mm]	55	75	85	60	80	100	65	85	115
Cracked concrete C20/25 to C50/60	Tension Load N	[kN]	5,7	9,5	13,2	5,1	8,2	11,7	5,7	8,6	14,4
	Displacement δ_{N0}	[mm]	0,4	0,4	0,4	0,3	0,4	0,6	0,3	0,4	0,7
		[mm]	0,4	0,4	0,5	0,9	0,9	1,2	1,3	1,3	1,5
Uncracked concrete C20/25 to C50/60	Tension Load N	[kN]	8,7	14,8	20,5	6,8	10,8	15,5	7,5	11,7	19,1
	Displacement δ_{N0}	[mm]	0,1	0,1	0,1	0,2	0,3	0,4	0,2	0,3	0,5
		[mm]	0,2	0,2	0,2	0,9	0,9	1,2	1,3	1,3	1,5

Fastener size HUS4			16								
Type			H(F)								
			h_{nom1}			h_{nom2}					
Nominal embedment depth	h_{nom}	[mm]	85								
Cracked concrete C20/25 to C50/60	Tension Load N	[kN]	8,7								
	Displacement δ_{N0}	[mm]	0,1								
		[mm]	1,3								
Uncracked concrete C20/25 to C50/60	Tension Load N	[kN]	11,5								
	Displacement δ_{N0}	[mm]	0,4								
		[mm]	1,3								

Hilti screw anchor HUS4

Performances
Displacement values in case of static and quasi-static loading

Annex C21

Table C19: Displacements under tension loads for HUS4 stainless steel

Fastener size HUS		6		8		10		14		
Type		HR, CR	HR, CR	HR, CR	HR, CR	H	H	HR		
		h_{nom}	h_{nom1}	h_{nom1}	h_{nom2}	h_{nom1}	h_{nom2}	h_{nom1}	h_{nom2}	
Nominal anchorage depth	h_{nom} [mm]	55	60	80	70	90	70	85	70	110
Cracked concrete C20/25 to C50/60	Tension load N [kN]	1,7	2,4	4,8	3,6	6,3	3,0	4,1	4,8	9,9
	δ_{N0} [mm]	0,4	0,5	0,7	0,3	0,6	0,2	0,3	0,9	1,4
	Displacement $\delta_{N\infty}$ [mm]	0,5	0,7	1,1	0,6	1,1	0,3	0,7	1,1	1,4
Uncracked concrete C20/25 to C50/60	Tension load N [kN]	3,1	4,8	6,3	6,3	9,9	4,8	6,8	7,5	16,0
	δ_{N0} [mm]	0,8	0,7	1,6	0,3	1,3	0,2	0,3	0,7	1,0
	Displacement $\delta_{N\infty}$ [mm]	0,8	0,7	1,6	0,3	1,3	0,3	0,7	0,7	1,0

¹⁾ No performance assessed.

Hilti screw anchor HUS4

Performances

Displacement values in case of static and quasi-static loading

Annex C22

Table C20: Displacements under shear loads for HUS4 carbon steel

Fastener size HUS4		8			8			10			
Type		H(F), C			T-H(F), T-C			H(F), C, A(F)			
		h_{nom}	h_{nom1}	h_{nom2}	h_{nom3}	h_{nom1}	h_{nom2}	h_{nom3}	h_{nom1}	h_{nom2}	h_{nom3}
Nominal embedment depth	h_{nom} [mm]	40	60	70	40	60	70	55	75	85	
Concrete C20/25 to C50/60	Shear Load V [kN]	10,7	10,7	12,5	8,1	8,1	8,1	16,5	16,5	18,3	
	Displacement δ_{v0} [mm]	1,3	1,1	0,9	2,5	3,4	2,9	1,4	1,3	1,0	
	Displacement $\delta_{v\infty}$ [mm]	2,0	1,7	1,4	3,7	5,1	4,4	2,1	2,0	1,5	

Fastener size HUS4		10			12			14				
Type		T-H(F), T-C			H(F)			H(F), A(F)				
		h_{nom}	h_{nom1}	h_{nom2}	h_{nom3}	h_{nom}	h_{nom1}	h_{nom2}	h_{nom3}	h_{nom1}	h_{nom2}	h_{nom3}
Nominal embedment depth	h_{nom} [mm]	55	75	85	60	80	100	65	85	115		
Concrete C20/25 to C50/60	Shear Load V [kN]		13,3			22,2	22,2	25,7	31,4	35,4	35,4	
	Displacement δ_{v0} [mm]	3,8	3,7	3,2	1,6	1,6	0,9	5,3	5,3	4,0		
	Displacement $\delta_{v\infty}$ [mm]	5,7	5,5	4,9	2,3	2,4	1,4	7,9	7,9	6,0		

Fastener size HUS4		16						
Type		H(F)						
		h_{nom1}			h_{nom2}			
Nominal embedment depth	h_{nom} [mm]		85			130		
Concrete C20/25 to C50/60	Shear Load V [kN]		37,2			41,8		
	Displacement δ_{v0} [mm]		2,3			1,8		
	Displacement $\delta_{v\infty}$ [mm]		3,5			2,7		

Table C21: Displacements under shear loads for HUS4 stainless steel

Fastener size HUS4		6		8		10		14	
Type		HR, CR		HR, CR		HR, CR		HR	
		h_{nom1}	h_{nom2}	h_{nom1}	h_{nom2}	h_{nom1}	h_{nom2}	h_{nom1}	h_{nom2}
Nominal anchorage depth	h_{nom} [mm]	55	60	80	70	90	70	110	
Concrete C20/25 to C50/60	Shear load V [kN]	7,8	11,0	12,4	13,6	15,7	12,9	27,3	
	Displacement δ_{v0} [mm]	0,4	2,0	2,3	1,1	1,7	3,5	3,9	
	Displacement $\delta_{v\infty}$ [mm]	0,5	2,4	2,9	1,5	2,4	3,9	4,3	
	$\delta_{v,C1}$ [mm]	1)	1)	4,8	1)	5,3	1)	7,6	

¹⁾ No performance assessed.

Hilti screw anchor HUS4

Performances
Displacement values in case of static and quasi-static loading

Annex C23

Table C22: Displacements under tension and shear loads for seismic category 2 for HUS 4 carbon steel

Fastener size HUS4 Type	8 H(F), C			8 T-H(F), T-C			10 H(F), C, A(F)		
	h_{nom2}	h_{nom3}	h_{nom1}	h_{nom2}	h_{nom3}	h_{nom1}	h_{nom2}	h_{nom3}	
Nominal embedment depth h_{nom} [mm]	60	70	50	60	70	55	75	85	
Tension load									
Displacement DLS $\delta_{N,C2}$ (DLS) [mm]		0,59			0,35			0,80	
Displacement ULS $\delta_{N,C2}$ (ULS) [mm]		1,36			0,65			3,66	
Shear load with Hilti filling set (HUS4-H and HUS4-A)									
Displacement DLS $\delta_{V,C2}$ (DLS) [mm]	3,57		1,85		3,37		1,81	4,32	1,72
Displacement ULS $\delta_{V,C2}$ (ULS) [mm]	5,56		5,44		5,38		4,60	7,72	6,88
Shear load without Hilti filling set									
Displacement DLS $\delta_{V,C2}$ (DLS) [mm]	3,57		4,64		3,37		3,93	4,32	5,02
Displacement ULS $\delta_{V,C2}$ (ULS) [mm]	5,56		7,96		5,38		5,55	7,72	8,97

Fastener size HUS4 Type	10 T-H(F), T-C			12 H(F)			14 H(F), A(F)		
	h_{nom1}	h_{nom2}	h_{nom3}	h_{nom1}	h_{nom2}	h_{nom3}	h_{nom1}	h_{nom2}	h_{nom3}
Nominal embedment depth h_{nom} [mm]	55	75	85	60	80	100	65	85	115
Tension load									
Displacement DLS $\delta_{N,C2}$ (DLS) [mm]		0,57			0,77			1,06	
Displacement ULS $\delta_{N,C2}$ (ULS) [mm]		2,08			2,78			3,89	
Shear load with Hilti filling set (HUS4-H and HUS4-A)									
Displacement DLS $\delta_{V,C2}$ (DLS) [mm]	4,07		1,80		4,05		1,73	4,00	2,52
Displacement ULS $\delta_{V,C2}$ (ULS) [mm]	7,50		4,03		7,07		5,62	6,09	6,79
Shear load without Hilti filling set									
Displacement DLS $\delta_{V,C2}$ (DLS) [mm]	4,07		4,15		4,05		4,90	4,00	4,93
Displacement ULS $\delta_{V,C2}$ (ULS) [mm]	7,50		6,15		7,07		7,00	6,09	9,14

Hilti screw anchor HUS4

Performances

Displacement values in case of seismic C2 loading

Annex C24